



FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1824

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

TSIGENIS A EVE T/A TSIGENIS WOODCRAFT

5km Heraklion - Finikia

Heraklion

71500

Greece

Tel: +302810373370

Who fabricate the following timber fire doors and or doorsets:

Halspan EI30, EI60.

Sauerland EI60.

have satisfied the requirements of the SDP01 Fire resistant Timber Door scheme. This includes the testing of products to **EN 1634-1**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity and insulation** are detailed on page 2 of this certificate.

Initial Certification: 22 February 2023

Reissued: 27 October 2023

Valid to: 21 February 2028

Issue number: 2

Ian Woodhouse

Head of Technical – IFC Certification

Kiwa Ltd

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*



The production of fire-resistant timber doorsets are manufactured in accordance with assessment/ test reports referenced within the following table:

Doorset Description	Fire Rating	Assessment/Test Report
Halspan 30	EI30	BMT/CAN/F13020
Halspan 60	EI60	BMT/FEA/F13021
42 VT Doorset (Doorset 2 only)	EI60	DMT_DO_50_776_R1

Signed on behalf of Kiwa Ltd

Ian Woodhouse
Head of Technical – IFC Certification
Kiwa Ltd

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

It is the certificate holder’s responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.

Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.

CERTIFICATE

